



August 05, 2026

ADDENDUM III

RFP Title: LC South Campus Parking Lot Project

To participants who are participants of the RFP# 26-0706

Addendum II: Questions and Answers:

- Will there be a bid form for this project?
 - Yes, please see the website for the form.
- Is there any landscaping work?
 - No, the construction documents are for reference on measurements, use the scope of work on the RFP.
- Asphalt transition details clarification:
 - Asphalt to Curb:
 - Mill or cut the existing edge for a clean vertical or sloped face.
 - Apply a heavy tack coat to the vertical face of the curb.
 - Place new asphalt flush or slightly high (1/4 inch) above the curb gutter line.
 - Roll and compact tightly against the curb.
 - Seal the joint with a hot-poured rubberized asphalt sealant.
 - Asphalt to Asphalt:
 - Saw-cut or mill the existing asphalt edge to create a straight, vertical joint (butt joint or a tapered mill keyway).
 - Clean all loose debris and dust from the cut edge.
 - Apply a tack coat to the vertical edge and base.
 - Place the new hot mix asphalt against the old edge.
 - Compact the joint with a roller and seal the surface seam with liquid asphalt sealant to prevent water entry. [[1](#), [2](#)]

Thank You,
Miguel A. Rangel
Director of Purchasing